



Office of the Regional Fire Officer
Karnataka Fire & Emergency Services,
Bangalore East Range.
Mayo Hall Fire Station Premises,
Residency Road, Bengaluru-560 025.

Phone No: 080-22971521

C.NO:24 /RFO/BLR-EAST/ADVICE/2025.

Dated: 03-11-2025

To
The Authorized Signatory,
M/s Janani Public School,
No: 43, Govt. College Road,
Kadugodi,
Bengaluru-560 037.

ANNEXURE-B

"B1 & B2 – Schools upto senior secondary level and other institutions"

Sir,

Sub: Issue of **"Fire Advisory Certificate"** with respect to Fire prevention; fire fighting and evacuation measures for the constructed Educational Building at **"M/s Janani Public School"**, NO:3, Govt. College Road, Kadugodi, Bengaluru-560 037.

Ref: 1. Yours request letter dated:-08-10-2025
2. NO:72/DFO/ITPLFS-BNG/2025, Dated:15-10-2025.

<<<>>>


With reference to the subject cited above, The District Fire Officer, ITPL Fire Station, EPIP, Whitefield, Bengaluru-560 066, has inspected the premises of **"M/s Janani Public School"**, NO:3, Govt. College Road, Kadugodi, Bengaluru-560 037 on **15-10-2025** with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	The President, M/s. Janani Public School, #43, Govt. College Road, Kadugodi, Bengaluru-560037.
----	------------------------------------	---	---



02	Name and Address of the premises.	:	M/s. Janani Public School, #43, Govt. College Road, Kadugodi, Bengaluru-560037.
03	Name and address of the Building owner	:	Authorised Signatory, Janani Educational and Social Welfare Trust, M/s. Janani Public School, #43, Govt. College Road, Kadugodi, Bengaluru-560037
04	Number of buildings	:	01 Building
05	Number of floors	:	Basement + Ground Floor + 05 Upper Floors
06	<u>Floor-wise details of occupancy:-</u>		
			<p><u>Basement</u> : Two Wheeler Parking, 01 Empty Room</p> <p><u>Ground Floor</u> : 01 Principal Room, 01 Room, 01 Conference hall, 01 VP Room, 01 President Room, 01 Secretary Room, 01 Store Room, 01 Reception</p> <p><u>1st Floor</u> : 09 Class Room, 01 Labs, 01 Staff Room, 01 Room</p> <p><u>2nd Floor</u> : 09 Class Room, 01 Library , 01 Staff Room, 01 Computer lab</p> <p><u>3rd Floor</u> : 13 Class Room, 01 Staff Room</p> <p><u>4th Floor</u>: 13 Class Room, 01 Staff Room</p> <p><u>5th Floor</u> : 08 Class Room</p>
07	Height of the building	:	20.10 Mtrs
08	Site area	:	0.75 Acres (3035.00 Sq. Mtrs)
09.	Built-up area of each floor:-		
		:	<p>Basement : 269.41 Sq. Mtrs</p> <p>Ground Floor : 867.20 Sq. Mtrs</p> <p>1st Floor : 867.20 Sq. Mtrs</p> <p>2nd Floor : 867.20 Sq. Mtrs</p> <p>3rd Floor : 867.20 Sq. Mtrs</p> <p>4th Floor : 867.20 Sq. Mtrs</p> <p>5th Floor : 473.99 Sq. Mtrs</p>
10.	Total built-up area	:	5079.40 Sq. Mtrs.
11.	Surrounding properties:-		
	North (Front)	:	11.00 Mtrs wide Junior College road
	South (Rear)	:	Railway Land
	East (Side)	:	Vacant Land and Industrial building
	West (Side)	:	Residential building



12.	<u>Set-back area available around the building :-</u>		
	North (Front)	:	Min 5.20 Mtrs
	South (Rear)		NIL
	East (Side)		NIL
	West (Side)		NIL

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)																					
01.	Accessibility to the premises	The premises is accessible from 11.00 Mtrs wide Junior College road located on the Northern Side. The road is hardened to carry weight upto 45,000 kgs.	The Requirement is complied with.																					
02.	No. of entrances	Provided 01 Entrance cum Exit	The Requirement is complied with.																					
03.	Width of entry / exit	01 Entrance cum Exit is of 5.90 Mtrs width.	The Requirement is complied with.																					
04.	Diesel generators.	Provided 01 Diesel Generator of 60 KVA capacity to supply alternate power to all the emergency provisions of the building.	The Requirement is complied with.																					
05.	No. of staircases available	<table border="1"> <tr> <td>Nos. of staircases</td> <td>:</td> <td>02 Nos</td> </tr> <tr> <td>Width of staircases</td> <td>:</td> <td>1. 1.10 Mtrs 2. 1.65 Mtrs</td> </tr> <tr> <td>Width of treads</td> <td>:</td> <td>30 Cms</td> </tr> <tr> <td>Height of risers</td> <td>:</td> <td>15 Cms</td> </tr> <tr> <td>Nos. of riser per flight</td> <td>:</td> <td>09 Nos</td> </tr> <tr> <td>Height of handrails</td> <td>:</td> <td>1. 1.00 Mtrs 2. 0.90 Mtrs</td> </tr> <tr> <td>Head room</td> <td>:</td> <td>More than</td> </tr> </table>	Nos. of staircases	:	02 Nos	Width of staircases	:	1. 1.10 Mtrs 2. 1.65 Mtrs	Width of treads	:	30 Cms	Height of risers	:	15 Cms	Nos. of riser per flight	:	09 Nos	Height of handrails	:	1. 1.00 Mtrs 2. 0.90 Mtrs	Head room	:	More than	The Requirement is complied with.
Nos. of staircases	:	02 Nos																						
Width of staircases	:	1. 1.10 Mtrs 2. 1.65 Mtrs																						
Width of treads	:	30 Cms																						
Height of risers	:	15 Cms																						
Nos. of riser per flight	:	09 Nos																						
Height of handrails	:	1. 1.00 Mtrs 2. 0.90 Mtrs																						
Head room	:	More than																						



		clearance		2.80 Mtrs	
06.	No. lifts and capacity.	Nos. of lifts	:	01 lift provided	The Requirement is complied with.
		Capacity of lifts	:	Provided lift of 13 passenger capacity.	
07.	Fire extinguisher	Provided following extinguishers all over the building.			The Requirement is complied with.
		Category	Capacity	Quantity	
		ABC	4.5 Kgs	21 Nos	
		Co2	4.5 Kgs	3 Nos	
		Water Type	9 Ltrs	02 No	
09.	First aid Hose reel hose/Down Comer/Wet Riser	Provided 01 No of Hose Reel Hose in each floor. Hose reel hoses are of minimum 19 mm size and of adequate length to reach the farthest point of each floor with shut off branch having a nozzle of 5 mm size at each floor. The hose reel hose connected by means of an adaptor.			Recommended to provide Down comer system. Each down comer should be of 100mm internal diameter and of G.I 'C' class pipe. From each down comer, single hydrant outlets should be provided. One down comer for every 1000 sq. Mtrs of built up area and it should be connected to 01 No of Terrace water tank of 25,000 Ltrs capacity which is connected to 1 Booster pump of capacity 900 LPM exclusively for fire fighting.
10.	Automatic sprinkler system.	Provided sprinkler system with 24 Nos of Sprinkler heads in Basement parking area.			The Requirement is complied with.
11.	Terrace tank over respective tower terrace/Underground Tanks	Provided 01 Terrace water tank of 5000 Ltrs Capacity. The Water tank is connected to Hose Reel Hose System.			Recommended to provide 01 Terrace water tank of 25,000 Ltrs capacity which should be connected to Down comer system with 1 Booster pump of capacity 900 LPM exclusively for fire fighting.



12.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	Provided 01 Electrical pump of 900 LPM Capacity in 4 th floor exclusively for fire fighting.	Recommended to shift the Electrical Fire pump to 5 th floor terrace area.
13.	Manually operated electronic Fire alarm system.	Not provided	Recommended to provide manually operated electrical fire alarms system with call boxes located near the emergency exit / appropriate places. The call boxes should be of 'Break Glass' type, where the call is transmitted automatically to the control room when the glass of the system is broken. This system should also be connected to an alternative source of power supply. The call boxes should be so installed that their location can easily be noticed from either direction and should be at a height of one meter from the floor level.
14.	Fire control room at ground floor.	Not provided	Recommended to provide;- a) Fire command centre shall be on the entrance floor of the building having direct access. b) Details of all floor plans along with the details of fire fighting equipment and installations (2 sets laminated and bound) shall be maintained in fire command centre.
15.	Escape routes	Marked Escape route with luminous light/paint at each floor directing towards exits and emergency exits.	The Requirement is complied with.
16.	Fire order	Provided Fire safety board indicating the details of actions to be taken in case of emergency displayed near each staircase landings with the telephone numbers of ITPL Fire Station 080-284 11101 and 101 number, 08022971500, 550 & telephone numbers of nearest Ambulance Service.	The Requirement is complied with.



17.	Fire fighting training	Not imparted	40% Occupants should get trained in fire prevention & fire fighting system at R.A. Mundkur Academy , Bannerghatta road, Bangalore - 560029
-----	------------------------	--------------	--

As such "Fire Advisory Certificate" is been issued for the constructed Educational Building, comprising of Basement, Ground and 5 Upper Floors at "M/s Janani Public School", NO:3, Govt. College Road, Kadugodi, Bangaluru-560 037 from fire prevention, fire fighting and Evacuation point of view subject to the compliance of below mentioned conditions within 03 months from the date of issue of "Fire Advisory Certificate".

1. Recommend to provide One Down comer system. The system provided should be extended to the 5th floor of the School Building. The down comer should be of 100mm Internal dia and should be of "G.I.C" Class pipe from each down comer single headed hydrant outlet should be provided at each floor landing.
2. The down comer should be connected to an overhead tank of 25,000 litres capacity with a booster pump capable of delivering 900 liters of water per minute.
3. Public Address system with two way communication facility with call points near each staircase landing and at each floor should be provided.
4. Manually operated Electric Fire Alarm system with call points near each staircase/ emergency exits at each floor with its control panel at Ground floor should be provided.
5. At least 40% of employees/ staff shall get trained in basic fire fighting at our R.A. Mundkur Fire & Emergency Services Academy, Bannerghatta Road, Bangalore.

Note:

1. The " Fire Advisory Certificate" issued by the Office/Fire Department is from fire safety point of view for the constructed low rise building. This shall not be considered as No Objection Certificate for the building.
2. After completion of all the fire fighting installations as advised in the "Fire Advisory Certificate". FIRE ADVISORY COMPLIANCE CERTIFICATE shall be obtained from this Office/Fire Department without fail.

Yours faithfully

A. Anant Kumar K
03/11/2025

Regional Fire Officer
Bengaluru East Range
Bengaluru

Copy.

To the District Fire Officer
Mayo Hall Fire Station Premises,
Residency Road, Bangalore.

ಪ್ರಾದೇಶಿಕ ಅಗ್ನಿಶಾಮಕ ಅಧಿಕಾರಿಯವರ ಕಛೇರಿ,
ಬೆಂಗಳೂರು ಪೂರ್ವ ವಲಯ,
ಕರ್ನಾಟಕ ರಾಜ್ಯ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳು,
ಮೆಯೋಹಾಲ್ ಅಗ್ನಿಶಾಮಕ ತಾಣ ಆವರಣ
ರೆಸಿಡೆನ್ಸಿ ರಸ್ತೆ, ಬೆಂಗಳೂರು-560025.



Phone No-080-22971521
Email Id- eastfoksfes@gmail.com

NO:128/RFO/BLR-EAST/CC/2025

Dated-28-11-2025.

To,
The Authorized Signatory
M/s Janani Public School & PU College
NO:43, Govt. College Road,
Kadugodi, Whitefield,
Bangalore-560037.

ಮಾನ್ಯರೇ,

ವಿಷಯ : **M/s Janani Public School & PU College**, ನಂ:43, ಸರ್ಕಾರಿ ಕಾಲೇಜ್ ಹತ್ತಿರ, ಕಾಡುಗೋಡಿ, ಬೆಂಗಳೂರು-560037 ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಸಮಾಪನ ಪತ್ರ ನೀಡುವ ಬಗ್ಗೆ.

- ಉಲ್ಲೇಖ : 1) ಕರ್ನಾಟಕ ರಾಜ್ಯ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳ ಮುಖ್ಯ ಕಚೇರಿಯ ಸಲಹಾ ಪತ್ರ ಸಂಖ್ಯೆ:24/ಪ್ರಾ.ಅ.ಅ./ಎಫ್.ಎಸ್.ಆರ್/2025 ದಿನಾಂಕ:03-11-2025.
2) ನಿಮ್ಮ ಪತ್ರ ದಿನಾಂಕ: 25-11-2025.
3) ಜಿಲ್ಲಾ ಅಗ್ನಿಶಾಮಕ ಅಧಿಕಾರಿ, ಇ.ಪಿ.ಐ.ಪಿ ತಾಣ ರವರ ವರದಿ ಸಂಖ್ಯೆ: 100/ಸಿಸಿ/ಜಿಅಅ/ಐ.ಟಿ.ಪಿ.ಎಲ್/2025, ದಿ:27-11-2025.

<<<<<<<>>>>>>>>

ನಂ:43, ಸರ್ಕಾರಿ ಕಾಲೇಜ್ ಹತ್ತಿರ, ಕಾಡುಗೋಡಿ, ಬೆಂಗಳೂರು-560037 ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡ 20.10 ತಳಹಂತ, ನೆಲಹಂತ ಮತ್ತು 05 ಮೇಲಂತಸ್ತುಗನ್ನು ಹೊಂದಿರುವ **M/s Janani Public School & PU College** ರವರ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯಿಂದ ದಿನಾಂಕ:03-11-2025 ರಂದು ನಿಮ್ಮ ಕೋರಿಕೆಯಂತೆ ಅಗ್ನಿ ಸಲಹಾ ಪತ್ರ ನೀಡಲಾಗಿದೆ.

ಉಲ್ಲೇಖ (2)ರ ನಿಮ್ಮ ಪತ್ರದಲ್ಲಿ, ಸದರಿ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಅಗ್ನಿಶಮನ ಉಪಕರಣಗಳ ಅಳವಡಿಕೆ ಕಾರ್ಯ ಮುಗಿದಿದ್ದು, ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯ ಸಮಾಪನ ಪತ್ರ ನೀಡುವಂತೆ ಕೋರಿರುವಿರಿ,

ನಿಮ್ಮ ಕೋರಿಕೆಯಂತೆ, ಜಿಲ್ಲಾ ಅಗ್ನಿಶಾಮಕ ಅಧಿಕಾರಿ, ಐ.ಟಿ.ಪಿ.ಎಲ್ ಅಗ್ನಿಶಾಮಕ ತಾಣ, ಕರ್ನಾಟಕ ರಾಜ್ಯ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳು, ಬೆಂಗಳೂರು ರವರು ದಿನಾಂಕ:27-11-2025 ರಂದು ನಂ:43, ಸರ್ಕಾರಿ ಕಾಲೇಜ್ ಹತ್ತಿರ, ಕಾಡುಗೋಡಿ, ಬೆಂಗಳೂರು-560037 ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಪರಿವೀಕ್ಷಣೆ ಮಾಡಿ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯು ನೀಡಿರುವ ಸಲಹಾ ಪತ್ರದಂತೆ, ಅಗ್ನಿರಕ್ಷಣೆ ಮತ್ತು ನಿಯಂತ್ರಣ,




ಅಗ್ನಿ ನಂದಿಸುವ ಉಪಕರಣಗಳ ಅಳವಡಿಕೆ ಹಾಗೂ ರಕ್ಷಣಾ ಕ್ರಮಗಳನ್ನು ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡದಲ್ಲಿ ಪೂರ್ಣವಾಗಿ ಅನುಷ್ಠಾನಗೊಳಿಸಿರುವುದಾಗಿ ಹಾಗೂ ಸದರಿ ಕಟ್ಟಡದಲ್ಲಿನ ನೌಕರರು/ಸಿಬ್ಬಂದಿಗಳಿಗೆ ಅಗ್ನಿಶಮನ ಕುರಿತ ತರಬೇತಿ ಮಾತ್ರ ಬಾಕಿ ಇರುವುದಾಗಿ ಹಾಗೂ ಸದರಿ ಕಟ್ಟಡದ ಸಮಾಪನ ಪತ್ರ ತರುವಾಯ ಅದರಲ್ಲಿನ ಸಿಬ್ಬಂದಿಗಳಿಗೆ ಅಗ್ನಿಶಮನ ಕುರಿತ ತರಬೇತಿ ವ್ಯವಸ್ಥಿಸಲು ಸಾಧ್ಯವಾಗುತ್ತದೆಂದು ತಿಳಿಸಿರುತ್ತಾರೆ.

ನಂ:43, ಸರ್ಕಾರಿ ಕಾಲೇಜ್ ಹತ್ತಿರ, ಕಾಡುಗೋಡಿ, ಬೆಂಗಳೂರು-560037 ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡ 20.10 ತಳಹಂತ, ನೆಲಹಂತ ಮತ್ತು 05 ಮೇಲಂತಸ್ತುಗಳನ್ನು ಹೊಂದಿರುವ **M/s Janani Public School & PU College** ರವರ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯ ಸಲಹಾ ಪತ್ರ ಸಂಖ್ಯೆ:24/ಪ್ರಾ.ಅಅ./ಎಫ್.ಎಸ್.ಆರ್/2025 ದಿನಾಂಕ:03-11-2025. ರಲ್ಲಿ ತಿಳಿಸಿರುವಂತೆ, ಅಗ್ನಿರಕ್ಷಣೆ ಮತ್ತು ನಿಯಂತ್ರಣ ಹಾಗೂ ಅಗ್ನಿ ನಂದಿಸುವ ಉಪಕರಣಗಳ ಅಳವಡಿಕೆ ಹಾಗೂ ರಕ್ಷಣಾ ಕ್ರಮಗಳನ್ನು ಕಟ್ಟುನಿಟ್ಟಾಗಿ ಪಾಲಿಸಬೇಕೆಂದು ಹಾಗೂ ನಿಮ್ಮ ಪತ್ರ ದಿನಾಂಕ:28-11-2025 ರ ಮುಚ್ಚಳಿಕೆ ಪತ್ರದಲ್ಲಿ ಒಪ್ಪಿರುವಂತೆ, ಅಗ್ನಿಶಮನ ಉಪಕರಣಗಳನ್ನು ಸುಸ್ಥಿತಿಯಲ್ಲಿಡಬೇಕೆಂಬ ಹಾಗೂ ಕಟ್ಟಡದಲ್ಲಿನ ಶೇಕಡಾ 40% ರಷ್ಟು ಸಿಬ್ಬಂದಿ/ನೌಕರರಿಗೆ ಅಗ್ನಿರಕ್ಷಣೆ ಮತ್ತು ನಿಯಂತ್ರಣ ಕ್ರಮಗಳ ಬಗ್ಗೆ ಬೆಂಗಳೂರಿನ ಆರ್. ಎ. ಮುಂಡ್ಕೂರ್ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳ ಅಕಾಡೆಮಿಯಲ್ಲಿ ಸೂಕ್ತ ತರಬೇತಿಯನ್ನು 03 ತಿಂಗಳೊಳಗೆ ಪಡೆಯಲು ವ್ಯವಸ್ಥಿಸಬೇಕೆಂಬ ಷರತ್ತಿನ ಮೇಲೆ ಸಮಾಪನ ಪತ್ರವನ್ನು ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಇಲಾಖೆಯಿಂದ ನೀಡಲಾಗಿದೆ. ಈ ಸಮಾಪನ ಪ್ರಮಾಣ ಪತ್ರವು ದಿನಾಂಕ:-02-11-2027 ರವರೆಗೆ ಚಾಲ್ತಿಯಲ್ಲಿರುತ್ತದೆ. ತದನಂತರ ಈ ಸಮಾಪನ ಪತ್ರವನ್ನು ನವೀಕರಿಸುವಂತೆ ತಿಳಿಸಲಾಗಿದೆ.

ಹಾಗೆಯೇ ಒಂದು ವೇಳೆ ಯಾವುದೇ ಸಂದರ್ಭದಲ್ಲಿ ಇಲಾಖೆಯ ಶಿಪಾರಸ್ಸಿನನ್ವಯ ಅಳವಡಿಸಿರುವ ಅಗ್ನಿನಿವಾರಣೆ ಹಾಗೂ ಅಗ್ನಿಶಮನ ಉಪಕರಣಗಳು ಸುಸ್ಥಿಯಲ್ಲಿರದೇ ಇರುವುದು ಕಂಡು ಬಂದರೆ ಅಥವಾ ರಕ್ಷಣಾ ಕ್ರಮಗಳನ್ನು ಕಟ್ಟುನಿಟ್ಟಾಗಿ ಪಾಲಿಸದಿದ್ದರೆ ಅಥವಾ ಕಾನೂನಿನನ್ವಯ ಸದರಿ ಕಟ್ಟಡದ ಸುತ್ತ ಬಿಟ್ಟಿರುವ ತೆರೆದ ಪ್ರದೇಶದಲ್ಲಿ ಯಾವುದೇ ಹೆಚ್ಚುವರಿ ರಚನೆಗಳನ್ನು ನಿರ್ಮಾಣ ಮಾಡಿದರೆ ಅಥವಾ ಯಾವುದೇ ರೀತಿಯ ಖಾಯಂ/ತಾತ್ಕಾಲಿಕ ಅಡಚನೆಗಳನ್ನು ಉಂಟು ಮಾಡಿದರೆ, ಈ ಸಮಾಪನ ಪತ್ರವು ಅನೂರ್ಜಿತಗೊಳ್ಳುವುದು ಹಾಗೂ ಕಾನೂನಿನ ಚೌಕಟ್ಟಿನಲ್ಲಿ ಮುಂದಿನ ಕ್ರಮ ಕೈಗೊಳ್ಳಲಾಗುವುದು ಎಂಬುದಾಗಿ ಸೂಚಿಸಲಾಗಿದೆ.

ತಮ್ಮ ವಿಶ್ವಾಸಿ

A. Armanth Kumar

ಪ್ರಾದೇಶಿಕ ಅಗ್ನಿಶಾಮಕ ಅಧಿಕಾರಿ
ಬೆಂಗಳೂರು ಪೂರ್ವ ವಲಯ
ಬೆಂಗಳೂರು

1) ಪ್ರತಿಯನ್ನು ಗೌರವಗಳೊಂದಿಗೆ,

ಮಾನ್ಯ ಪೋಲೀಸ್ ಮಹಾ ನಿರ್ದೇಶಕರು ಹಾಗೂ ಮಹಾ ನಿರ್ದೇಶಕರು,
ಕರ್ನಾಟಕ ರಾಜ್ಯ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳು.